



**CORRIGENDUM-1**

**Subject : Tender No: HBC/P-S/PUBLIC TENDER 01/2024**

**Name of the work: SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF 1000A L&T OMEGA AIR CIRCUIT BREAKER RETROFITTING IN TO EXISTING PANEL AT NIUS SUBSTATION AND SERVICING AND TESTING OF 3 NO'S OF LT ACB'S AT HOMI BHABHA CENTRE FOR SCIENCE EDUCATION, TIFR, MANKHURD, MUMBAI-400088 FOR THE YEAR 2024-2025.**

Dear Bidders/Vendors,

Reference subject tender published on CPPP portal, HBCSE and TIFR website on January 01, 2024 the following amendment (**bold and underlined**) to the subject is issued for tender document. Bidders are requested to kindly submit their quotations with full knowledge of following amendments-

**1. Scope of work**

**8. Technical specifications (Page No: -19) : - Sr. No. 5 A – Other requirement should**

**read as :**

<b>Parameter No. 5</b>	<b>Specifications &amp; Requirements</b>	<b>Whether Agreed by the firm (Yes/No)</b>
Other Requirement	a) Two free services in warranty period. Onsite Breaker Operation and Maintenance Training shall be conducted to HBCSE and Contract employees. Two sets of operation and Maintenance Manual.  b) SITC of 230V under voltage coil  c) SITC of UV relay with wiring	Yes/No

**All other tender conditions remain unchanged.**

  
(Pragati Dandekar)  
Head Administrative Operations