HOMI BHABHA CENTRE FOR SCIENCE EDUCATION Minutes of the Technical Committee Meeting

June 18,2025

Minutes of the Pre-bid meeting held for the Street lights Tender at HBCSE

A pre-bid meeting for the installation of street lights tender was held on 16th June, 2025 at 11:00 am. In room no. G1, Main building.

The following members of HBCSE represented the pre -bid meeting.

- 1. Mr. Srikanth Banda, Indenter
- 2. Mr. Manish Thakur-Purchase Representive

The representatives from the following firms attended the pre- bid meeting.

- 1. M/s. RS Enterprises
- 2. M/s. Anamika Enterprises

The representatives were informed about the requirements of the tender and the detailed information about the requirement was provided i.e. Scope of work, Job discerption, Bill of quantities, quality of work and financial bid explanation etc. in the meeting. Some representatives raised few quires which were replied by the HBCSE members as follows:

1. **M/s RS Enterprises** repetitive raised a query regarding the earthing arrangement for street light poles, specifically seeking clarification on the requirement for pole-to-pole earthing. –

Response given- The individual pole-to-pole earthing is mandatory as part of this project. Each pole must be provided with a separate and properly installed earthing system, in accordance with applicable standards such as IS 3043 or equivalent.

2. **M/s Anamika Enterprises** repetitive raised a query regarding the warranty period, asking whether it is for 5 years. Additionally, he inquired whether a Hume pipe or an MS (Mild Steel) pipe is to be used for the installation-

Response given- The manufacturer's warranty should be for a period of 5 years. If the party is awarded the order, they must submit the warranty cards accordingly. The decision regarding the use of Hume pipe or MS pipe shall be finalized by the Engineer-in-Charge (EIC) at the time of installation.

The meeting concluded at 12:00 Hrs.